

Licensee: McDonald's Australia Limited
 Premises: 23 Maitland Rd, Hexham NSW 2322
 Licence: 329

Monitoring Frequency: Monthly

<https://app.epa.nsw.gov.au/prpoeoapp/Detail.aspx?instid=329&id=329&option=licence&searchrange=licence&range=POEO%20licence&prp=no&status=Issued>

Updated 28 October, 2020



McDonalds Hexham: Water Testing Results - September 2020 to August 2021 from Point 2 as listed in EPA Licence

Parameter	Unit of Measurement	Sep-20	Oct-20	Nov-20	Dec-20	Jan-21	Feb-21	Mar-21	Apr-21	May-21	Jun-21	Jul-21	Aug-21
Sample Date		28/09/2020	16/10/2020										
Date Data was Obtained		19/10/2020	28/10/2020										
Published Date		21/10/2020	28/10/2020										
Biochemical Oxygen Demand	Milligrams per litre	2.00	3.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Enterococci	cfu per 100 mL	1.00	1.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Faecal Coliforms	cfu per 100 mL	1.00	1.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
MBAS	Milligrams per litre	0.10	0.10	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Nitrogen (ammonia)	Milligrams per litre	1.74	0.37	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Nitrogen (total)	Milligrams per litre	2.20	16.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Oil and Grease	Milligrams per litre	5.00	5.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
pH	pH	7.10	6.80	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Phosphorus (total)	Milligrams per litre	3.10	5.40	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Suspended Solids	Milligrams per litre	30.00	28.40	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

EPA Licence L3 Concentration Limits

Parameter	Units	Concentration Limits
Oil & Grease	milligrams per litre	10
pH	pH	6.5 - 8.5
Faecal Coliforms	cfu per 100 mL	100
Suspended Solids	milligrams per litre	30
Biochemical Oxygen Demand]	milligrams per litre	20
Enterococci	cfu per 100 mL	100

Monitoring and Discharge Points per EPA Licence

Point 2: M1 - Monitoring Point on grassed area of the land to the west of the site.

Point 3: D1 - Discharge of treated water is piped under Maitland Road and into Hexham River

Reasons for Limits being Exceeded

N/A